



# FILMTEC Membranes

## FILMTEC SW30HR-380 High Rejection Seawater RO Element


The FILMTEC™ SW30HR-380 is a premium grade seawater reverse osmosis element featuring both high active area and high salt rejection to offer the best long-term economics for seawater desalination systems.

- SW30HR-380 delivers the highest boron rejection to help customers meet World Health Organization (WHO) and other drinking water standards.
- SW30HR-380 elements deliver high performance over their operating lifetime without the use of oxidative post-treatments like many competitive products. This is one reason why FILMTEC elements are more durable and may be cleaned more effectively over a wide pH range than other RO elements.
- Automated, precision fabrication with a greater number of shorter membrane leaves, reduces the overall effect of fouling and maximizes membrane efficiency.

### Product Specifications

Product	Part Number	Active Area ft <sup>2</sup> (m <sup>2</sup> )	Applied Pressure psig (bar)	Permeate Flow Rate, gpd (m <sup>3</sup> /d)	Stabilized Salt Rejection (%)
<b>SW30HR-380</b>	135137	380 (35)	800 (55)	6,000 (23)	99.7

1. Permeate flow and salt rejection based on the following test conditions: 32,000 mg/l NaCl, pressure specified above, 77°F (25°C), pH 8 and 8% recovery.
2. Permeate flows for individual elements may vary +/-15%.
3. Minimum salt rejection is 99.6%.
4. Product specifications may vary slightly as improvements are implemented.



FilmTec supplies coupler part number 129768 with each element. Each coupler includes two 3-912 EPR o-rings (FilmTec part number 151705).

Product	Dimensions – Inches (mm)		
	A	B	C
<b>SW30HR-380</b>	40.0 (1016)	1.125 (29)	7.9 (201)

5. Refer to FilmTec Design Guidelines for multiple-element systems.
6. SW30HR-380 fits nominal 8-inch (203 mm) I.D. pressure vessel.

1 inch = 25.4 mm

### Operating Limits

Membrane Type ..... Polyamide Thin-Film Composite  
 Maximum Operating Temperature ..... 113°F (45°C)  
 Maximum Operating Pressure ..... 1000 psig (69 bar)<sup>d</sup>  
 Maximum Pressure Drop ..... 15 psig (1.0 bar)  
 pH Range, Continuous Operation<sup>a</sup> ..... 2–11  
 pH Range, Short-Term Cleaning (30 min.)<sup>b</sup> ..... 1–12  
 Maximum Feed Silt Density Index (SDI) ..... SDI 5  
 Free Chlorine Tolerance<sup>c</sup> ..... <0.1 ppm

<sup>a</sup> Maximum temperature for continuous operation above pH 10 is 95°F (35°C).

<sup>b</sup> Refer to Cleaning Guidelines in specification sheet 609-23010.

<sup>c</sup> Under certain conditions, the presence of free chlorine and other oxidizing agents will cause premature membrane failure. Since oxidation damage is not covered under warranty, FilmTec recommends removing residual free chlorine by pretreatment prior to membrane exposure. Please refer to technical bulletin 609-22010 for more information.

<sup>d</sup> Operation at pressures up to 1200 psig (83 bar) is allowable under certain conditions. Consult your Dow representative for advice on applications above 1000 psig (69 bar).

\*Trademark of The Dow Chemical Company

# FILMTEC Membranes

For more information about FILMTEC membranes, call the Dow Liquid Separations business:  
North America . . . . . 1-800-447-4369  
Latin America . . . . . (+55) 11-5188-9277  
Europe . . . . . (+32) 3-450-2240  
Japan . . . . . (+81) 3-5460-2100  
Australia . . . . . (+61) 2-9776-3226  
<http://www.filmtec.com>

## Important Information

Proper start up of reverse osmosis water treatment systems is essential to prepare the membranes for operating service and to prevent membrane damage due to overfeeding or hydraulic shock. Following the proper start up sequence also helps ensure that system operating parameters conform to design specifications so that system water quality and productivity goals can be achieved.

Before initiating system start up procedures, membrane pretreatment, loading of the membrane elements, instrument calibration and other system checks should be completed.

Please refer to the application information literature entitled "How to

Start Up an RO Membrane System" (Form No. 609-00070) for more information.

## Operation Guidelines

Avoid any abrupt pressure or cross-flow variations on the spiral elements during start-up, shutdown, cleaning or other sequences to prevent possible membrane damage. During start-up, a gradual change from a standstill to operating state is recommended as follows:

- Feed pressure should be increased gradually over a 30-60 second time frame.
- Cross-flow velocity at set operating point should be achieved gradually over 15-20 seconds.
- Permeate obtained from first hour of operation should be discarded.

## General Information

- Keep elements moist at all times after initial wetting.
- If operating limits and guidelines given in this bulletin are not strictly followed, the limited warranty will be null and void.
- To prevent biological growth during prolonged system shutdowns, it is recommended that membrane elements be immersed in a preservative solution.
- The customer is fully responsible for the effects of incompatible chemicals and lubricants on elements.
- Maximum pressure drop across an entire pressure vessel (housing) is 50 psi (3.4 bar).
- Avoid static permeate-backpressure at all times.

**Notice:** The use of this product in and of itself does not necessarily guarantee the removal of cysts and pathogens from water. Effective cyst and pathogen reduction is dependent on the complete system design and on the operation and maintenance of the system.

**Notice:** No freedom from any patent owned by Seller or others is to be inferred. Because use conditions and applicable laws may differ from one location to another and may change with time, Customer is responsible for determining whether products and the information in this document are appropriate for Customer's use and for ensuring that Customer's workplace and disposal practices are in compliance with applicable laws and other governmental enactments. Seller assumes no obligation or liability for the information in this document. NO WARRANTIES ARE GIVEN; ALL IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY EXCLUDED.

Published July 2002.



\*Trademark of The Dow Chemical Company

Form No. 609-00390-702QRP